

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated: 11.03.2025

It is certified that an inspection team headed by Satyabrata Majhi, Asst. Eng.

(Name of Officers with designation) from RWS & S Paikmal PHED

inspected the Mahamaya Public School, Paikmal, Dist. Bargarh

(Name & Address of the school) on 10.03.2025 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. dated 11.03.2025

of Sub-divisional Laboratory, Padampur (PHED Lab) certified that the

Mahamaya Public School, Paikmal (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till 5 years (i.e. 11.03.2030)

Signature with Seal:

Name

Designation

Name & Address of the Office / Department :

To Mahamaya Public School

Paikmal

(Name & Address of the Institution)

RWS & S Section Paikmal

At/PO- Paikmal

Dist- Bargarh

Odisha.

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

SUB-DIVISIONAL LABORATORY **RWS&S SUB-DIVISION, PADAMPUR**

The water quality report of the water samples of following locations
of Village- Paikmal , G.P- Paikmal under Paikmal Block.

LOCATION – Mahamaya Public School

- 1- Borewell**
- 2- Filter**

TESTING DATE :- 11/03/2025

S.N	Chloride in mg/ltr	Hardness in mg/ltr	Iron in mg/ltr	Fluoride in mg/ltr	PH in range	TDS in mg/ltr	Alkalinity in mg/ltr	Turbidity in NTU	Conductivity in μ S/cm	Bacteria
	Permissible limit 1000 mg/ltr	Permissible limit 600 mg/ltr	Permissible limit 1.0 mg/ltr	Permissible limit 1.5 mg/ltr	6.5 - 8.5	Permissible limit 2000 mg/ltr	Permissible limit 600 mg/ltr	Permissible limit 5 NTU		
1	168 mg/ltr	156 mg/ltr	0.22 mg/ltr	0.98 mg/ltr	7.55	181 mg/ltr	160 mg/ltr	1.9	402	Not Found
2	160 mg/ltr	148 mg/ltr	0.21 mg/ltr	0.88 mg/ltr	7.50	179 mg/ltr	152 mg/ltr	1.4	418	Not Found

Amey K. Bhoi
Lab Assistant 11/03/2025
Sub - Divisional laboratory,
Sub-Divisional Water testing Laboratory
Padampur
RWS&S Sub Division Padampur